SUBMITTAL DATA



MODEL C-S/R-WTS (Single Blade)

Ceiling Damper for Wood Truss Systems U.L. 555C CLASSIFIED ASSEMBLIES AND ULC S112.2 LISTED Approved for 1 - Hour Wood Truss Floor/Ceiling Assemblies

Application and Design

The Model C-SR-WTS is a rectangular UL Classified ceiling (radiation) damper, single blade style, approved for steel duct, flex duct and ductless installations in approved UL ceiling/floor designs as listed below**. These dampers provide protection up to 9" x 18" openings.

2

D-1/8

10"

3"


Plaster flange

depth

(⁵/₈" std.)

Standard Construction

(gauge as required by UL)



Springs: Corrosion resistant steel spring Fusible Link: Replaceable 165°F (75°C) std. (212° F optional)

Designed and tested in accordance to standards: UL 555C, ULC S112.2. Labeled and listed by UL/ULC under File# R25411. They meet all the NFPA-90A, IBC Code , and other major code requiremenets for Ceiling (Radiation) Dampers.

Note:

Due to continuing research, UE reserves the right to change specifications without notice.

Standard Sizes (duct)		
Min. Size (W x H)	Max. Size (W x H)	*Inlet size (D)
6" x 4" [152mm x 102mm]	9" x 18" 229mm x 457mm	4"Ø (102mm) min. 12"Ø (305mm) oval equivalent (max.)

*Duct connections may be provided as oval equivalent. **Intended for installation in Fire Resistance Design No. M520 as detailed in the UL Fire Resistance Directory

and are similar to fire resistance rated ceiling constructions represented in the International Building Code.

on) damper, single ns in approved UL ction up to 9" x 18" —		
Plaster flange width (1-1/4" std.) C-SR-WTS	Side A Side B L 13" max., (std.)	
	(+) H and W are actual I.D. Dimensions.	
Options:	UL approved with steel and aluminum diffuser	
🗌 Boot Rail		
🗌 Inlet Conne	ection	
Round/C	Dval Equivalent 🔲 Square/Rectangular	

Side: 🗌 A 🔲 B

☐ Alternate Plaster Flange

- □ 1-1/4" deep x 1-1/4" wide
- □ 2" deep x 1-1/4" wide □ 3" deep x 1-1/4" wide
- □ Alternate 212° F (100°C) fusible link

SUGGESTED SPECIFICATION

Wood Truss Ceiling dampers shall be model C-S/R-WTS by CVS. Ceiling dampers shall bear the UL label and be rated for both steel duct and flex duct installations. No external damper supports shall be required for ceiling dampers up to and including 162 sq. inch. in area. Ceiling dampers shall be non asbestos type and be firnished with a fusible link. Volume controller furnished where shown.

Manufacturer's Recommendations

All moving parts of the damper must be inspected and cycled once the first year and at intervals not greater than every 4 years or in accordance with the latest edition of NFPA 90A, 92A, local codes. In addition, fuse links shall be removed and inspected for corrosion. Dry lubricants are recommended.

I C-S/R-WTS le Blade)
le blade)